MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: YEL-P/PMC/SCU

Date: 24/01/2021

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Retaining Wall 2nd Lift and Column Concrete	27-12-2021	24-01-2022	8.20	28	551.00	24.49	24.19
2		"	"	8.21	"	564.00	25.07	
3		"	"	8.65	"	534.00	23.73	
4		"	"	8.30	"	560.00	24.89	
5		"	"	8.45	"	521.00	23.16	
6		"	"	8.64	"	536.00	23.82	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: YEL-P/PMC/SCU

Date: 08/01/2022

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table 1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Retaining Wall 3rd Lift Concrete	01-01-2022	08-01-2022	8.33	7	398.00	17.69	17.98
2		"	"	8.41	"	409.00	18.18	
3		"	"	8.30	"	435.00	19.33	
4		"	"	8.10	"	410.00	18.22	
5		"	"	8.00	"	395.00	17.56	
6		"	"	8.25	"	380.00	16.89	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: YEL-P/PMC/SCU

Date: 29/01/2022

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Retaining Wall 3rd Lift Concrete	01-01-2022	29-01-2022	8.21	28	500.00	22.22	23.20
2		"	"	8.23	"	531.00	23.60	
3		"	"	8.28	"	546.00	24.27	
4		"	"	8.10	"	540.00	24.00	
5		"	"	8.15	"	505.00	22.44	
6		"	"	8.43	"	510.00	22.67	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: YEL-P/PMC/SCU

Date: 13/01/2022

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Slab Concrete	06-01-2022	13-01-2022	8.61	7	425.00	18.89	17.36
2		"	"	8.34	"	416.00	18.49	
3		"	"	8.51	"	375.00	16.67	
4		"	"	8.56	"	367.00	16.31	
5		"	"	8.41	"	381.00	16.93	
6		"	"	8.23	"	379.00	16.84	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

MOBILE:99

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: YEL-P/PMC/SCU

Date: 03/02/2022

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Slab Concrete.	06-01-2022	03-02-2022	8.41	28	532.00	23.64	23.36
2		"	"	8.35	"	543.00	24.13	
3		"	"	8.27	"	525.00	23.33	
4		"	"	8.22	"	555.00	24.67	
5		"	"	8.35	"	512.00	22.76	
6		"	"	8.14	"	486.00	21.60	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

HRIYA CONSTRUCTION AND CONSULTANCY
#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

Date: 13/01/2022

NO: YEL-P/PMC/SCU

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Slab Concrete	06-01-2022	13-01-2022	8.22	7	418.00	18.58	17.51
2		"	"	8.41	"	385.00	17.11	
3		"	"	8.25	"	392.00	17.42	
4		"	"	8.63	"	376.00	16.71	
5		"	"	8.45	"	384.00	17.07	
6		"	"	8.32	"	409.00	18.18	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

MOBILE:99[illegible]

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

Date: 03/02/2022

NO: YEL-P/PMC/SCU

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- Providing Kannada words/Alphabets and Sculptures in the premises of Allalasandra and Yelahanka lake in Yelahanka Assembly Constituency

Ref: Material Testing/PMC/21-22.

Report submitted to: Assistant Executive Engineer, Yelahanka Projects Division, BBMP Bangalore.

Name of Agency/ contractor: M/s NPR Infratech(Sri N Purushotham Raju) .

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table 1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Slab Concrete	06-01-2022	03-02-2022	8.00	28	533.00	23.69	22.94
2		"	"	8.23	"	514.00	22.84	
3		"	"	8.35	"	529.00	23.51	
4		"	"	8.17	"	548.00	24.36	
5		"	"	8.59	"	494.00	21.96	
6		"	"	8.65	"	479.00	21.29	

SHRIYA CONSTRUCTION AND CONSULTANCY

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92